

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION  
OFFICE OF THE STATE FIRE MARSHAL  
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

# LISTING SERVICE

**LISTING No.** 4485-1017:106 Page 1 of 1

**CATEGORY:** Opening Protection (Firestopping)

**LISTEE:** Nelson Firestop Products, 4041 S. Sheridan, Tulsa, OK 74145  
Contact: \*Richard Emerson (918) 627-5530

**DESIGN:** Model CPS composite sheet. The composite sheet is a 0.34" thick rigid sheet faced on one side with aluminum foil and the other side with galvanized steel sheet. Refer to listee's data sheet and UL Fire Resistance Directory for additional detailed product description and considerations.

**INSTALLATION:** In accordance with listee's printed installation instructions, UL Fire Resistance Directory, applicable codes & ordinances and in a manner acceptable to the authority having jurisdiction.

**MARKING:** Listee's name, product name and UL label.

**APPROVAL:** Listed as firestop sheet for use in through penetration fire stop system for concrete floor or wall assembly up to 1 hour rating. For indoor use only. Approved UL System: CAJ-0050.

\*Rev. 07-06-2000



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued:

**JUNE 12, 2002**

*Listing Expires **June 30, 2003***

Authorized By:

**DIANE K. AREND**, Senior Deputy  
Program Manager